

DCEW-131(1550) RS485 連接設備參考範例

Setup x +

⚠ 不安全 | 192.168.1.250/html/infosetup.html

Converter Setup

Local IP	192.168.1.250		
Subnet mask	255.255.255.0		
Gateway IP	192.168.1.254		
DHCP client	Disable		
Remote Host IP	0.0.0.0		
Remote Host port	0		
SIO Port, Type	502	TCP Server	▼
SIO BaudRate	19200	N	8 2
SIO Type	RS485 (Half Duplex)		
SIO Packets Gap	200	ms	
MODBUS/TCP	Enable		
Slave Response Time out	1000	ms	
Device ID			
Setup password			
Access password			
Multi Sockets Arbitration Time	0	ms	

Note: SIO Port 502 is Reserved for the MODBUS/TCP.